

Evidence of Performance

Door handles and door knobs according to EN 1906 : 2012



Test Report

No. 13-003305-PR01

(PB DB-G03-03-en-03)

Client Häfele GmbH & Co
Adolf-Häfele-Str 1
72202 Nagold
Germany

Product Door handle set / door handle / door handle

Designation PDH3101 Rosette fittings
PDH3102 Rosette fittings
PDH3103 Rosette fittings
PDH3104 Rosette fittings
PDH3107 Rosette fittings

Performance-relevant product details Material handle: stainless steel,
Storage turn fixed,
Square spindle: 8.0 mm,
Material square spindle: steel

Installation According to the installation instructions by the hardware manufacturer

Special features

Basis

EN 1906 : 2012

Prüfnormen:


EN 1906 : 2012

Corresponds to the national versions (e. g.. DIN EN)

Test Report 12-003211-PR01
(PB-G03-03-de-01)
dated 14.11.2012

Test Report 13-003305-PR01
(PB-G03-03-de-02)
dated 23.10.2013

Representation



Instruction for use

This test report serves to demonstrate the requirements of door handles and door knobs EN 1906 : 2012.

Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented; in particular the effects of weathering and ageing were not taken into account.

Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

The report contains a total of 21 pages.

Results

Classification according to EN 1906 : 2012

Category of use	Durability	Door mass	Fire resistance	Safety	Corrosion resistance	Burglar resistance	Design
3	7	-/-	0	0	4	0	B

Square spindle: 8.0 mm, material: steel, storage: turn - fixed

ift Rosenheim

07.11.2013

Alexander Sauer, Dipl.-Ing. (FH)
Operating Product Officer
Building Components

Gerd Steiner
Head of Laboratory
Mechanics